Via Vicenza 45
31050 VEDELAGO (TV)
Tel 0423 400621
Fax 0423 401177

CERTIFICATE OF CONFORMITY: COPPER TUBE COATED WITH CROSS LINKED PE FOAM

In accordo con: EN 10204 –2.2

CUSTOMER	**AB KLIMA**
ITEM CODE	**2RGECGRE#GC075A**

COPPER TUBE

St N°: 2647

NOMINAL DIMENSION [mm]		**3/8" x 0,80 mm**
NORM		**EN 12735-1 / CUSTOMER TECHNICAL SPECIFICATIONS**
ITEM NAME		**GREEN**
CHEMICAL COMPOSITION		**CU-DHP**
PHYSICAL STATE		**ANNEALED**
TENSILE STRENGTH	**[MPa]**	**> 220**
ELOGANTION	**[%]**	**> 40**
MARKING	**FEINROHREN ITALIA CU-DHP ANNO TRIM**	

CROSS LINKED PE FOAM

Code:

037#A30B060057NAT

Propriety	Norm	Required	Result
DENSITY [Kg/m³]	**ISO 845**	**30**	**OK**
THICKNESS [mm]		**7**	**OK**
WATER VAPOR DIFFUSION RESISTANCE [μ]	**EN 12086:2013**	**>9000**	**OK**
THERMAL CONDUCTIVITY AT 0°-40°C [W/m K]	**EN 12667:2001**	**0,0400<λ<0,0430**	**OK**
MARKING	**<Mt.99> GEL Ø 3/8 X 0,8 Euroclass Bs2d0 EN 13501-1 <logo CE> GAS R410A-R32 <linea-data>**		

THIS DOCUMENT CERTIFIES THAT THE PRODUCT COMPLIES WITH THE AGREED SPECIFICATIONS